

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-0410:139 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621-2268  
Contact: \*Bob Misiuk (714) 670-3251

**DESIGN:** Model ATA-EA detector with Model YBC-RL/2NC or YBF-RL/2NBE base. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, rating and UL label.

**APPROVAL:** Listed as a heat detector for use with Fike Model 10-201 control unit (CSFM Listing No. 7165-0900:106).

\*Rev. 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager